

SANDIA REPORT

SAND2009-1171

Unlimited Release

Printed March 2009

Wind Turbine Reliability Database Update

Roger R. Hill, Valerie A. Peters, Jennifer A. Stinebaugh and Paul S. Veers

Prepared by
Sandia National Laboratories
Albuquerque, New Mexico 87185 and Livermore, California 94550

Sandia is a multiprogram laboratory operated by Sandia Corporation,
a Lockheed Martin Company, for the United States Department of Energy's
National Nuclear Security Administration under Contract DE-AC04-94AL85000.

Approved for public release; further dissemination unlimited.

Issued by Sandia National Laboratories, operated for the United States Department of Energy by Sandia Corporation.

NOTICE: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government, nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors, or their employees, make any warranty, express or implied, or assume any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represent that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government, any agency thereof, or any of their contractors or subcontractors. The views and opinions expressed herein do not necessarily state or reflect those of the United States Government, any agency thereof, or any of their contractors.

Printed in the United States of America. This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from
U.S. Department of Energy
Office of Scientific and Technical Information
P.O. Box 62
Oak Ridge, TN 37831

Telephone: (865) 576-8401
Facsimile: (865) 576-5728
E-Mail: reports@adonis.osti.gov
Online ordering: <http://www.osti.gov/bridge>

Available to the public from
U.S. Department of Commerce
National Technical Information Service
5285 Port Royal Rd.
Springfield, VA 22161

Telephone: (800) 553-6847
Facsimile: (703) 605-6900
E-Mail: orders@ntis.fedworld.gov
Online order: <http://www.ntis.gov/help/ordermethods.asp?loc=7-4-0#online>



SAND2009-1171
Unlimited Release
Printed March 2009

Wind Turbine Reliability Database Update

Roger R. Hill, Valerie A. Peters, Jennifer A. Stinebaugh, and Paul S. Veers
Wind Energy Technology Department
Sandia National Laboratories
P.O. Box 5800
Albuquerque, NM 87185-1124

Abstract

This report documents the status of the Sandia National Laboratories' Wind Plant Reliability Database. Included in this report are updates on the form and contents of the Database, which stems from a five-step process of data partnerships, data definition and transfer, data formatting and normalization, analysis, and reporting. Selected observations are also reported.

Contents

INTRODUCTION	7
OBJECTIVES OF THE WIND PLANT RELIABILITY DATABASE AND ANALYSIS PROGRAM	8
PROGRAM ACTIVITIES FROM INCEPTION THROUGH FY08	8
THE NATIONAL RELIABILITY DATABASE	9
DATA PARTNERSHIPS	9
DATA DEFINITION AND TRANSFER	10
SCADA DATA.....	10
WORK ORDER DATA.....	11
SUMMARIZED DATA	11
DATA CHALLENGES	12
DATA FORMATTING AND NORMALIZATION	12
ANALYSIS PROCESS	13
REPORTING AND ANALYSIS OUTPUT	14
PARTNER REPORT - SAMPLE	14
SUMMARY STATISTICS.....	15
APPENDIX A – TAXONOMY	19
TAXONOMY (TOP 2 LEVELS).....	25
APPENDIX B – REPORT TEMPLATE FOR INDIVIDUALIZED REPORTS TO PARTNERS	26
APPENDIX C: PRO-OPTA	27
IMPORT SETUP	27
DATA ANALYZER	27
DATA MANAGER	27
FAULT TREE INTERFACE	28
RESULTS MODULE	28
OPTIMIZER	28
APPENDIX D: BLADE RELIABILITY SURVEY	29

Figures

FIGURE 1: TURBINE TIME ALLOCATION PIE CHART	16
FIGURE 2: AVAILABILITY AND UTILIZATION TRENDS.....	17
FIGURE 3: COST PERFORMANCE DRIVERS	17
FIGURE 4: COST HIGH VARIABILITY DRIVERS.....	18

Tables

TABLE 1: SUMMARY STATISTICS – PLANT VS. NATIONAL	15
TABLE 2: TURBINE SUMMARY STATISTICS	18

Introduction

The goal of Sandia's Wind Plant Reliability Database and Analysis Program is to characterize the reliability performance of the US fleet to serve as a basis for improved reliability and increased availability of turbines. The Wind Plant Reliability Database and Analysis Program is designed to fill a need identified by wind plant owners and operators to better understand wind turbine component failures so efforts can be focused to resolve these failures and /or mitigate the consequences, resulting in improved operations and reduced maintenance costs. With sufficient participation across the fleet, benchmarking of fleet-wide reliability performance will characterize the industry as a whole. Characterization of reliability issues will help prioritize and facilitate R&D efforts to foster component and system design improvements. Together these actions are aimed at reducing financial and technical risks for a growing wind energy market.

Sandia has historically been engaged in system reliability research activities in safety, materials, and fatigue. The broad-based expertise and capabilities that evolved from this engineering of numerous critical systems is now being applied to wind energy systems. For example, wind turbines have mission requirements of high reliability to perform under specified conditions for established durations of time. Failures, events, repairs, and replacements will all have impacts on turbine and plant availability, and cost of operation.

A national vision of 20% of electrical demand supplied by wind energy (cite the 20% energy plan) has been published by the Department of Energy (DOE). To accomplish a market penetration of this magnitude the following must occur:

- Wind turbines must be an economically competitive technology
- Risks to reliable plant performance must be manageable
- The technology must have strong public acceptance based on proven performance
- Policies that promote renewable energy must be put in place and maintained

Plant availability is a key metric of performance for wind plants as it is directly related to energy production and revenues. Energy is not generated while components are being repaired or replaced. Although a single failure of a critical component stops production from only one turbine, such losses can add up to significant sums of lost revenue. An availability increase will improve economics, reduce risks, and provide relevant contributions toward meeting 20% penetration goals. An improvement in overall fleet availability performance of 1 percentage point will result in an additional 12,000,000 MWH for the US and \$600 M in additional revenue for operators, at 20% wind penetration.

The consequences of real or perceived reliability problems extend beyond the direct cost to the plant owners. Long-term loans are used to finance power plants that are heavy with upfront capital costs such as wind plants. Financial institutions assess the risk of investing in wind energy and set interest rates accordingly. Reducing the risk of unpredictable or unreliable performance improves the ability to finance projects. As financial institutions gain confidence in wind power, insurance and financing costs could decrease, thus increasing the competitiveness and use of wind energy.

Objectives of the Wind Plant Reliability Database and Analysis Program

The goals of any wind plant reliability program are to improve availability, reduce costs of Operations and Maintenance (O&M), and maintain high levels of production.

To help wind plants reach these goals, the Wind Plant Reliability Database and Analysis Program has a mission to *characterize* reliability performance issues and *identify* opportunities for improving reliability and availability performance of the national wind energy infrastructure.

The following program objectives will help move the industry toward improved reliability:

- Guide DOE program Research and Development (R&D) investment through identification of critical issues, including determination of relative impact of component failures
- Provide data for root cause analyses of component failures
- Establish national benchmarks for reliability
- Guide industry actions for improved equipment performance and operating practices
- Provide data partners with benchmarking of their own equipment against national benchmarks
- Give specific feedback assessments to partners: operators, owners, asset managers, and equipment suppliers
- Identify components that result in highest cost, highest downtimes, and/or lowest availability, and which would be the best candidates for revised O&M practices, or other types of improvement
- Facilitate a culture change in wind plant operation to more effectively monitor and utilize reliability information

Part of the Program's goal is to help increase availability through well understood and numerically characterized reliability performance of component and systems. Reliability analysis is for the purposes of efficient planning. In this case, planning will include understanding failure rates, forestalling failures, managing efficient repairs and replacements, and having optimum spares inventory. Individualized reliability reports for each data partners will contribute to efficient planning. Published reports of aggregated reliability statistics of the US fleet, when sufficient numbers are included, will provide benchmarks of reliability performance and also trend reliability improvements over time.

Program Activities from Inception through FY08

Since the inception of the Wind Plant Reliability Database and Analysis Program, a number of actions have been undertaken to help meet the above objectives, including structuring the necessary industry collaborations and creating a process to collect, analyze, identify, and disseminate critical failure modes and areas for improvements in system reliability. Activities to date include:

- Two Wind Turbine Reliability Workshops with industry (2006, 2007)
- Background O&M investigations at selected wind plant sites
- Publication of *Wind Turbine Reliability: Understanding and Minimizing Wind Turbine Operation and Maintenance Costs*, Sand2006-1100
- Publication of *Wind Turbine Reliability: A Database and Analysis Approach*, Sand2008-0983

- Development of the National Reliability Database
- A survey conducted on blade reliability, with results reported at Sandia’s Blade Workshop in June 2008
- Non-disclosure agreements (NDAs) signed with over a half dozen parties
- Development of a reporting template for use with individualized data reports
- Development of a Wind turbine taxonomy (component breakdown)

The National Reliability Database

Many industries, including fossil fueled power generation, have established anonymous databases that serve to benchmark their reliability and performance, giving operators both the ability to recognize a drop in reliability and the data they need to determine the source of low reliability. In mature industries, O&M management tools are available to help maximize maintenance efficiency. Achieving this efficiency is a key factor in minimizing the cost of energy (COE) and maximizing the life of wind plants, thereby increasing investor confidence.

The backbone of the Wind Plant Reliability Database and Analysis Program is the National Reliability Database, which houses the data used to develop the statistics and analytical reports. The database uses a Structured Query Language (SQL) server, housed on computing resources owned by Sandia National Laboratories. This option offers cost effective data security with the firewall exemptions necessary for data transfer from partners located outside Sandia.

The database architecture was originally developed by ARES Corporation and is described in SAND 2006-1100 D. This database has been tested with data from an initial partner with operational data transferred to the database. Data from SCADA (Supervisory Control and Data Acquisition) files and work orders comprise the database at this time. (See the section on “Data Definition and Transfer” for more information on these data sources.)

There are five key steps in aggregating diverse industry experience from across the country into summary reports, which supply the fundamental information to achieve program goals. As explained in the following sections, the steps are:

1. Data Partnerships
2. Data Definition and Transfer (what data will be used, how to transfer it, etc.)
3. Data Formatting and Normalization
4. Analysis
5. Reporting and Analysis Output

Data Partnerships

The Wind Plant Reliability Database and Analysis Program is based on the acquisition of operational data to determine basic reliability statistics of wind turbines deployed throughout the United States. It is in the operation of wind plants that reliability data of components are recorded. Outage events, faults, and failures contribute to the unreliability observed in the plant or individual turbines. Other types of reliability-related O&M data include the spare parts and human and equipment resources needed to perform preventative and corrective maintenance. Much of this data resides in plant SCADA systems and work orders.

The process to acquire data from partners requires some effort from the partners. Typically, data partners need to provide electronic or other forms of access to the SCADA and work order systems. Whether electronic or otherwise, SCADA codes, work orders, and operational practices will need to be understood for proper analysis. In exchange for the data, data partners are provided with individual reliability reports. Examples of such reports are provided in the section on “Reporting and Analysis Output” and a full sample report is provided in Appendix B.

Ensuring protection of information is critical for successful partnerships. Sandia and potential wind plant owners and operators prepare, review and sign non-disclosure agreements (NDAs) requiring that neither Sandia nor the data partner will share raw data or analysis results with parties outside the agreement. The process has become somewhat standardized as additional partnerships are formed. The NDA also makes clear that data provided will be used for purposes of aggregation into the US fleet National Reliability Database, but no individual contribution will ever be identified or attributed to a specific wind plant.

Data Definition and Transfer

The data needed is that which contributes to answering the basic questions of **how often** something fails, **how long** is it out of operation, and **how much** the down time costs. In other words, the symptoms, cause, and corrective actions for any failure or maintenance activity need to be determined.

To determine answers to these questions, the following information is required for reliability analysis:

- For each downtime event:
 - Turbine ID: Distinguishes individual turbines
 - Event Code: Unique identifier for type of downtime event
 - Event Name: Descriptive label for type of downtime event
 - Event Type: Type of downtime (e.g., failure, preventative maintenance)
 - Event Cost: Cost per occurrence and/or hour of downtime
- In general:
 - Monitoring period: First and last day the turbine was monitored for downtime events
 - Turbine operating hours: Total time, during the monitoring period, that the turbine was operating (generating)
 - Turbine idle time: Total time, during the monitoring period, that the turbine was capable of operating (i.e., not down for any reason), but was not operating. (Examples of this time include no wind or curtailment)

There are potentially vast amounts of data (billions of data points) and this data differs from wind plant to wind plant. The data needed for reliability comes down to three types – Supervisory Control and Data Acquisition (SCADA), work orders, and summarized data.

SCADA Data

A subset of the data from every turbine’s control system, as well as data collected at the metering, substation, and grid connection interface, is stored in the plant-wide Supervisory Control and Data Acquisition (SCADA) system. When an operator or the control system shuts a turbine down, that

shutdown is recorded and stored in the SCADA system. In addition to data capture, SCADA systems can generate reports that summarize monthly outages and power production. These reports may also be part of the data gathered from partners.

There are several ways SCADA data can be transferred to Sandia for input into the National Reliability Database:

- Direct SCADA access (via network connection to the SCADA system) where systems will be set up and maintain the connection to get this data. This method of data transfer will require interaction with data partner staff to set up the connection.
- Web access, if the SCADA has a web-based client that Sandia staff can access.
- Transfer of data by data partner staff, using an acceptable electronic format (including comma separated value (CSV), MS Excel spreadsheets, SQL database output, and any other format that can be easily transferred into a SQL database). Transfer can be accomplished via e-mail, CD/DVD, or FTP.

Work Order Data

Work orders are often generated by plant managers to capture the need for repairs or other types of maintenance. A work order may have multiple purposes. It may be used for tracking of human resources, or for tracking the time the turbine spent offline. For purposes of reliability tracking, work orders may document the investigation into the cause of outage and which component failed and/or was replaced. In this way, work orders may provide insight into turbine performance and document operator actions which indicate the root cause of failure.

Work orders can be used for normal preventative maintenance. Scheduled maintenance activities, which may not be recorded in the SCADA system, will be identified by work orders. It is important to account for these actions as they contribute to turbine unavailability, in the strictest sense. Ideally, work order systems will be computerized in an automated maintenance management system.

Currently, both SCADA and work orders are being used for input into the National Reliability Database and for analysis. These two sources provide raw data. Transferring raw data ensures that Sandia is responsible for the assumptions used to summarize the data – leading to a standardized and uniform approach in creating a baseline and benchmarking the industry. With the lower level of detail offered by raw data, many types of analysis become possible, including exploring variability within a farm, comparing turbines, exploring trends and correlation with greater detail (ex: hourly vs. monthly), exploring lost opportunity costs of downtime (in terms of generation kW and/or dollars), and exploring the wind's impact on generation and downtime.

If electronic work orders are not available, data partners provide copies of paper work orders to Sandia. However, work order information available electronically is greatly preferred and facilitates timely reports back to the data partner.

Summarized Data

Summarized data includes monthly or annual operating reports, survey data, or other types of downtime and maintenance event information not reported through SCADA or Work Orders. Examples could include fault and failure logs, outage reports, parts consumption histories, etc. Having less data to

transfer and store is a benefit of obtaining summarized data. Another feature is that it shifts the data summarizing to the operator or data partner. However, when less detail is provided, detailed analysis will be more limited. For purposes of reliability reporting, analyses would be based on summaries from the data partner. Comparing or combining data across multiple data partners would require an effort to standardize or normalize the data to obtain equivalency of input data. To meet the goal of data from 10% of the installed wind capacity by 2012, the sheer magnitude of data may necessitate use of some form of summarized data. In most cases, this summary information can be determined by assessing SCADA and work order data.

To conduct reliability analysis using summarized data, the following information is needed for each type of downtime or maintenance:

- Event Code: Unique identifier for event type
- Event Name: Descriptive label for event type
- Event Rate (single value and/or distribution)
- Downtime Duration (single value and/or distribution)
- Event Type: Type of downtime, e.g., failure, preventative maintenance
- Event Cost: Cost per occurrence and/or hour of downtime

Data Challenges

Failure data for plant equipment and processes likely contains issues with the definition of “failure,” data accuracy, data recording ambiguities, data accessibility, and incomplete cost information. It is difficult to identify a base set of “downtimes” for the turbine when SCADA and work order data do not match. When a downtime period is determined, it may be difficult to identify the cause for that downtime. While SCADA codes are faithfully recorded, the actual component that caused the event is often not identified explicitly. Work orders give insight into the failure cause and repairs performed, but they are not generated each time the turbine goes down. Often, work orders list the amount of time it took for the operator to fix the turbine, not the actual time the turbine was down.

Costs for parts replacement, repair, and maintenance activities are useful for assessing expenses and can help determine inventory spares, and total system impacts.

Data Formatting and Normalization

Wind plants have many different methods for gathering and processing their data. Although turbine manufacturers collect similar data values, the data points are structured, stored, named, and aggregated in a variety of ways. An understanding of these differences and a standardized approach for inputs into the database are necessary. To get data into the National Reliability Database, the proper structure must be in place to import the data. For SCADA data, this is usually a fairly straightforward process, as data can be put into comma separated value (CSV) format or exported to an Excel spreadsheet.

As part of data entry for the database, SCADA event codes are matched to a generic physical breakdown of wind turbine components. A wind turbine taxonomy has been developed by the Wind Plant Reliability Database and Analysis Program (see Appendix A for the taxonomy breakdown) that lists the components and subcomponents of most modern wind turbines. SCADA codes from the data partners’ plant SCADA systems are each matched to a single component in this taxonomy. For example, a SCADA code by the name of “Generator Overspeed Sensor” would be matched to the

“Generator::Shaft::Encoder” component in the taxonomy. Once the data has been entered and matched to the appropriate component, analysis can begin.

Work order data is also entered into the National Reliability Database. The process entails preparing electronic work order data into the proper format so that the information matches the fields in the database tables. Paper work orders must be transferred by manually inputting the information into the database table. This is a time consuming process, but the information in the work orders is valuable as a useful work order will contain information regarding symptom, cause and corrective action.

Analysis Process

Once data is gathered from a data partner, normalized, and entered into the National Reliability Database, it is ready for analysis. First, individualized reporting and analysis is performed for each data partner. Then, the set of data from all partners is analyzed collectively to develop a national baseline for the industry, which is used to produce national-level reporting and analysis.

The software used to perform the analysis is a powerful Sandia-developed reliability analysis tool called Pro-Opta. Pro-Opta has been used in many technologies and operations ranging from fleets of mobile units to logistically complex operational installations to production facilities (see Appendix C for more information on Pro-Opta).

Features of Pro-Opta include:

- Analysis of system performance (availability, mean time between failure, downtime, reliability, and cost), based on field failure and maintenance data. Reporting includes analysis of overall plant, individual turbines, and weak-link analysis of individual failure modes' contributions to performance.
- An optimization to identify the best reliability and O&M improvements, given a variety of what-if scenarios/trade-offs and user-defined goals/objectives (e.g., minimize Annual Cost and Weight, while simultaneously maximizing Availability).
- An optimization to identify the ideal spare parts inventory, given user-defined goals/objectives (e.g., maximize Availability, while simultaneously minimizing the Inventory's total volume). Both optimizations can simultaneously model multiple designs/plants, including those that share some, but not all, failure modes and/or inventory items.
- Consolidation of field failure and maintenance data into a fault tree model of the system (including O&M costs, calculation of uncertainties and probability distributions, and estimates of correlation between failure modes).

Reporting and Analysis Output

Reporting and analysis is performed on two levels – national baseline reports and partner reports. National Baseline Reports illustrate the national performance of the wind energy industry as a whole. These reports document performance, highlight unexpected (both positive and negative) findings, and make TIO (Technology Improvement Opportunity) recommendations. Partner Reports are provided to each of our data partners illustrating their wind plant(s) performance and comparing this to the national baseline. In addition to the partner report, custom analysis may be performed for partners with specific questions, as time and resources permit.

Partner Report - Sample

Partner reports contain graphs, charts, and analysis results intended to address two distinct needs: understanding of the individual plant's performance, and comparing an individual plant against the national baseline. Depending on the structure of the NDA with the partner, this may also include comparing a single plant against other plants owned by the same entity. The following paragraphs and figures illustrate a sample of the type of reporting that will be created for partners. (See Appendix B for a complete sample report.) Also included in the sample report are definitions for the reliability terms listed in the figures. Due to the proprietary nature of the data and the program, actual results cannot be shown for a partner data; thus, these charts and values are not based on actual data, but are intended for illustration purposes. National statistics are not yet ready for publication, but reliability models will be delivered in FY09.

The report begins with high-level "Summary Statistics" of the plant's performance, which is contrasted with National performance, as shown in Table 1: Summary Statistics – Plant vs. National below. This information creates a one-page "Executive" summary of the plant's performance. In addition to this summary for all maintenance and downtime events at the plant, the Failures, Faults, and Scheduled Maintenance are called out separately.

Summary Statistics

Events Included	Metric	<i>Last 6 Months (1/1-6/30/08)</i>		<i>All Available Data</i>	
		Plant Mean Value	National Mean Value	Plant Mean Value	National Mean Value
All Events	Operational Availability	X%	X%	X%	X%
	Wind Utilization	X%	X%	X%	X%
	Utilization	X%	X%	X%	X%
	MTBE (operating hrs)	X	X	X	X
	Mean Downtime (hrs)	X	X	X	X
	Annual Cost (per Turbine)	\$X	\$X	\$X	\$X
Failures	Intrinsic Availability	X%	X%	X%	X%
	MTBF (operating hrs)	X	X	X	X
	Mean Failure Downtime (hrs)	X	X	X	X
	Annual Failure Cost (per Turbine)	\$X	\$X	\$X	\$X
Faults	MTB Fault (operating hrs)	X	X	X	X
	Mean Fault Downtime (hrs)	X	X	X	X
	Annual Fault Cost (per Turbine)	\$X	\$X	\$X	\$X
Scheduled Maintenance	MTB Scheduled Maintenance (operating hrs)	X	X	X	X
	Mean Scheduled Downtime (hrs)	X	X	X	X
	Annual Scheduled Cost (per Turbine)	\$X	\$X	\$X	\$X

All metrics, including annual cost, are for a single, representative, turbine

Table 1: Summary Statistics – Plant vs. National

Another key summary element of the report is the “Time Allocation” chart, which illustrates how a typical turbine spends an average month. Time is broken out based on Generation and Wind, with subcategories where appropriate, as illustrated below in Figure 1: Turbine Time Allocation Pie Chart. This allows for multiple definitions of availability and utilization to be explored from within a single graph.

		Wind			
		Below Cut In < 4 m/s	Low 4-15 m/s	Rated 15-25 m/s	Above Cut Out > 25 m/s
Generation	Rated, > 90% Nominal Capacity	[Green Grid]	[Dark Green Diagonal]	[Green Solid]	[Light Green Check]
	Moderate, 10-90%	[Yellow Grid]	[Dark Yellow Diagonal]	[Yellow Solid]	[Brown Check]
	Low, 0.01-10%	[Orange Grid]	[Dark Orange Diagonal]	[Orange Solid]	[Brown Check]
	None, 0% Turbine Online	[Red Grid]	[Dark Red Diagonal]	[Red Solid]	[Red Check]
	Turbine Offline	[Cyan Grid]	[Dark Cyan Diagonal]	[Cyan Solid]	[Light Cyan Check]
Unknown		[White]			




Figure1: Turbine Time Allocation Pie Chart

The report also provides trending information for both the plant and the National baseline including Availability, Utilization, Mean Downtime, Mean Time Between Events, Cost, and Event Counts. An example Availability/Utilization trend graph is shown below in Figure 2: Availability and Utilization Trends.




Figure 2: Availability and Utilization Trends

In addition to information about the performance of the plant as a whole, various wind turbine components are analyzed and Pareto charts are created to show both their contributions to overall performance and overall turbine-to-turbine variability. These Pareto charts are created for Availability, Event Frequency, Downtime, and Cost. The value of these charts is to show what events have the greatest effect on turbine performance. This knowledge creates an understanding of areas of reduced reliability performance at the component level and can help operators prioritize how they approach maintenance, develop spares strategies, and implement technologies such as condition based maintenance (CBM) that can help proactively decrease failure rates. See Figure 3: Cost Performance Drivers. Additionally, variability drivers are events which affect the uncertainty in reliability metrics. This is illustrated in Figure 4: Cost High Variability Drivers, with the most significant negative effect on the certainty of the metric listed. Larger variability implies bigger differences from turbine to turbine and more risk when planning for reliability impacts.




Figure 3: Cost Performance Drivers




Figure 4: Cost High Variability Drivers

Along with exploring the performance of the various components, individual performance for each turbine is also calculated. This information allows for comparison across turbines or sections of a plant, and allows for “weak links” to be quickly detected. See Table 2: Turbine Summary Statistics, below, for an example.

Turbine	Operational Availability	Mean Time Between Events (hours)	Average Cost Per Event	Mean Downtime Per Event (hours)
Turbine 0001	X%	X	\$X	X
Turbine 0002	X%	X	\$X	X
Turbine 0003	X%	X	\$X	X
Turbine 0004	X%	X	\$X	X
Turbine 0005	X%	X	\$X	X
Turbine 0006	X%	X	\$X	X
Turbine 0007	X%	X	\$X	X
Turbine 0008	X%	X	\$X	X
Turbine 0009	X%	X	\$X	X
Turbine 0010	X%	X	\$X	X
...

Table 2: Turbine Summary Statistics

Appendix A: Taxonomy

The following taxonomy has been developed for the Wind Plant Reliability Database and Analysis Program. All data will be associated with one of the components listed.

Blade

- Blade::Aero-dynamic brake
- Blade::Internal structure - laminates
- Blade::Lightning protection
- Blade::Paint and coatings
- Blade::Skins - laminates
- Blade::T-bolt/root insert
- Blade::De-icing system

Rotor

- Rotor::Nose cone
- Rotor::Pitch system
 - Rotor::Pitch system::Linear hydraulic drive
 - Rotor::Pitch system::Linear hydraulic drive::Accumulator
 - Rotor::Pitch system::Linear hydraulic drive::Pump
 - Rotor::Pitch system::Linear hydraulic drive::Pump motor
 - Rotor::Pitch system::Linear hydraulic drive::Proportional valve
 - Rotor::Pitch system::Linear hydraulic drive::Miscellaneous hydraulic
 - Rotor::Pitch system::Linear hydraulic drive::Position sensor
 - Rotor::Pitch system::Linear hydraulic drive::Hose/fitting
 - Rotor::Pitch system::Linear hydraulic drive::Spherical bushing
 - Rotor::Pitch system::Linear hydraulic drive::Cylinder
 - Rotor::Pitch system::Linear hydraulic drive::Bushing
 - Rotor::Pitch system::Linear hydraulic drive::Linkage
 - Rotor::Pitch system::Linear hydraulic drive::Position controller
 - Rotor::Pitch system::Linear hydraulic drive::Limit switch
 - Rotor::Pitch system::Rotary electric drive
 - Rotor::Pitch system::Rotary electric drive::Motor
 - Rotor::Pitch system::Rotary electric drive::Gear reducer
 - Rotor::Pitch system::Rotary electric drive::Pinion
 - Rotor::Pitch system::Rotary electric drive::Motor cooling fan
 - Rotor::Pitch system::Rotary electric drive::Motor brake
 - Rotor::Pitch system::Rotary electric drive::Power electronics/drive
 - Rotor::Pitch system::Rotary electric drive::Cabling
 - Rotor::Pitch system::Rotary electric drive::Contactor/circuit breaker.fuse
 - Rotor::Pitch system::Rotary electric drive::Battery
 - Rotor::Pitch system::Rotary electric drive::Battery charger
 - Rotor::Pitch system::Rotary electric drive::Encoder
 - Rotor::Pitch system::Rotary electric drive::Limit switch
 - Rotor::Pitch system::Rotary electric drive::Power supply
 - Rotor::Pitch system::Rotary electric drive::Heater

- Rotor::Pitch system::Rotary electric drive::Miscellaneous electrical
- Rotor::Pitch system::Mechanical drive
 - Rotor::Pitch system::Mechanical drive::Bearings
 - Rotor::Pitch system::Mechanical drive::Gears
 - Rotor::Pitch system::Mechanical drive::Motor
 - Rotor::Pitch system::Mechanical drive::Pitch cylinder linkage
- Rotor::Pitch system::Pitch gear
- Rotor::Pitch system::Bearing
 - Rotor::Pitch system::Bearing::Seal
 - Rotor::Pitch system::Bearing::Auto-lube system
- Rotor::Hub
- Rotor::Slip ring assembly
- Rotor::Root attachment
 - Rotor::Root attachment::Bolts

Drivetrain

- Drivetrain::Low speed shaft
 - Drivetrain::Low speed shaft::Main bearing
 - Drivetrain::Low speed shaft::Main shaft
 - Drivetrain::Low speed shaft::Main bearing seal
 - Drivetrain::Low speed shaft::Compression coupling
 - Drivetrain::Low speed shaft::Rotor lock
- Drivetrain::High speed shaft
 - Drivetrain::High speed shaft::High speed coupling
 - Drivetrain::High speed shaft::Transmission shaft
- Drivetrain::Braking system
 - Drivetrain::Braking system::Brake disc
 - Drivetrain::Braking system::Brake calipers
 - Drivetrain::Braking system::Brake pads
 - Drivetrain::Braking system::Transmission lock

Gearbox

- Gearbox::Bearings
 - Gearbox::Bearing::Planet bearing
 - Gearbox::Bearing::Carrier bearing
 - Gearbox::Bearing::Shaft bearing
- Gearbox::Gears
 - Gearbox::Gears::Planet gear
 - Gearbox::Gears::Ring gear
 - Gearbox::Gears::Sun gear
 - Gearbox::Gears::Spur gear
 - Gearbox::Gears::Hollow shaft
- Gearbox::Lube system
 - Gearbox::Lube system::Cooling system
 - Gearbox::Lube system::Cooling system::Coolant pump
 - Gearbox::Lube system::Cooling system::Radiator
 - Gearbox::Lube system::Primary filtration

- Gearbox::Lube system::Secondary filtration
- Gearbox::Lube system::Lube pump
- Gearbox::Lube system::Lube pump motor
- Gearbox::Lube system::Hose/fitting
- Gearbox::Lube system::Reservoir
- Gearbox::Lube system::Sensor
- Gearbox::Housing
- Gearbox::Torque arm system
 - Gearbox::Torque arm system::Bushing

Generator

- Generator::Cooling system
 - Generator::Cooling system::Filter
 - Generator::Cooling system::Cooling fan
 - Generator::Cooling system::Pump
 - Generator::Cooling system::Pump motor
 - Generator::Cooling system::Reservoir
 - Generator::Cooling system::Radiator
 - Generator::Cooling system::Hose/fitting
- Generator::Stator
 - Generator::Stator::Winding
 - Generator::Stator::Lamination
- Generator::Rotor
 - Generator::Rotor::Winding
 - Generator::Rotor::Lamination
 - Generator::Rotor::Encoder
 - Generator::Rotor::Shaft
- Generator::Controller::Exciter
- Generator::Controller::Resistance controller
- Generator::Controller::Slip ring
- Generator::Controller::Brush
- Generator::Housing
- Generator::Commutator and brushes
- Generator::Bearings
 - Generator::Bearings::Auto-lube system

Electrical

- Electrical::Power converter
 - Electrical::Power converter::IGBT module
 - Electrical::Power converter::Rectifier bridge
 - Electrical::Power converter::Crowbar system
 - Electrical::Power converter::Driver/control board
 - Electrical::Power converter::Harmonics filter
- Electrical::PFC system
 - Electrical::PFC system::Capacitors
 - Electrical::PFC system::Harmonics filter
 - Electrical::PFC system::Contactor

- Electrical::Soft starter
- Electrical::Wiring and connections
- Electrical::Grounding system
- Electrical::Main transformer
 - Electrical::Main transformer::Pad mounted transformer
 - Electrical::Main transformer::Nacelle-mounted transformer
- Electrical::Components
 - Electrical::Components: Main contactor
 - Electrical::Components: Main circuit breaker
 - Electrical::Components: Main disconnect
 - Electrical::Components: Motor contactor
 - Electrical::Components: Power supply
 - Electrical::Components: Fuse
 - Electrical::Components: Relay
 - Electrical::Components: Cabinet heater
 - Electrical::Components: Miscellaneous

Nacelle

- Nacelle::Enclosure
- Nacelle::Meteorological equipment
 - Nacelle::Meteorological equipment::Anemometer
 - Nacelle::Meteorological equipment::Anemometer::De-icing heater
 - Nacelle::Meteorological equipment::Wind vane
 - Nacelle::Meteorological equipment::Temperature sensor
- Nacelle::FAA lights
- Nacelle::Internal environment
 - Nacelle::Internal environment::Nacelle heater
 - Nacelle::Internal environment::Nacelle vent
 - Nacelle::Internal environment::Nacelle lighting
- Nacelle::Crane

Yaw

- Yaw::Cable twist/untwist
- Yaw::Brake
 - Yaw::Hydraulics::Accumulator
 - Yaw::Hydraulics::Pump
 - Yaw::Hydraulics::Hoses and valves
 - Yaw::Hydraulics::Motor
- Yaw::Drives
 - Yaw::Drives::Motor
 - Yaw::Drives::Gear reducer
 - Yaw::Drives::Pinion
- Yaw::Bearings (slew ring)
- Yaw::Gear
 - Yaw::Gear::Lubrication system
- Yaw::Damper
- Yaw::Hydraulics

Control system

Control system::Sensors

Control system::Sensors::Static::Generator temp

Control system::Sensors::Static::Particulate sensor

Control system::Sensors::Static::Power metering

Control system::Sensors::Static::Yaw position proximity

Control system::Sensors::Static::Gearbox temp

Control system::Sensors::Dynamic::Vibration sensors

Control system::Communications

Control system::SCADA interface

Control system::Controller

Control system::Controller::Software

Control system::Controller::Central processor

Control system::Controller::I/O board

Control system::Controller::Power supply

Control system::Controller::User interface

Control system::Cabinet

Control system::UPS

Control system::UPS::Battery

Foundation and tower

Foundation and tower::Foundation

Foundation and tower::Foundation::Bolts

Foundation and tower::Tower structure

Foundation and tower::Tower structure::Paint and coatings

Foundation and tower::Tower structure::Bolts

Foundation and tower::Tower equipment

Foundation and tower::Tower equipment::Climb assist

Foundation and tower::Tower equipment::Ladder/hatches/internals

Balance of plant

Balance of Plant::Substation

Balance of Plant::Substation::VAR Control system (Reactive Power control)

Balance of Plant::Substation::Potential transformers

Balance of Plant::Substation::Breakers

Balance of Plant::Substation::Current transformers

Balance of Plant::Substation::Lightning arrestors

Balance of Plant::Substation::Switching

Balance of Plant::Substation::Power transformers (Volt adj.; load tap chngs)

Balance of Plant::Substation::Power transformers::Power compensation

Balance of Plant::Met tower

Balance of Plant::Meteorological tower::Anemometer

Balance of Plant::Meteorological tower::Wind vane

Balance of Plant::Meteorological tower::Barometer

Balance of Plant::SCADA

Balance of Plant::SCADA::Server


Balance of Plant::SCADA::Communications switch

- Balance of Plant::SCADA::Cabling
- Balance of Plant::SCADA::Cooling
- Balance of Plant::SCADA::Software
- Balance of Plant::Converter
- Balance of Plant::Grid connection
 - Balance of Plant::Grid connection::Utility communication
- Balance of Plant::Collection and distribution
- Balance of Plant::Metering and relays

Maintenance

- Maintenance::Troubleshooting
- Maintenance::Fault reset
- Maintenance::Scheduled maintenance
 - Maintenance::Scheduled maintenance::3-month-int
 - Maintenance::Scheduled maintenance::6-month-int
 - Maintenance::Scheduled maintenance::12-month-int
- Maintenance::Miscellaneous
 - Maintenance::Miscellaneous::Punch list
 - Maintenance::Miscellaneous::QC punch list
 - Maintenance::Miscellaneous::Emergency stop

Taxonomy (Top 2 levels)



**Appendix B: Report Template for individualized reports to
Partners**

National Wind Energy Reliability Database

Wind Plant Data Partner Report

COMPANY: Company X

PLANT: Plant A

Report Date: 6/30/2008



Table of Contents

TABLE OF CONTENTS	2
TABLE OF FIGURES	3
TABLE OF TABLES	4
SUMMARY STATISTICS	5
DEFINITIONS & TERMS	6
AVERAGE TIME ALLOCATION	8
PARTS REPLACEMENT SUMMARY	9
TRENDS	10
PERFORMANCE DRIVERS – ROLL UP	12
<i>Operational Unavailability Performance Drivers – Rollup</i>	12
<i>Event Frequency (MTBE) Performance Drivers – Rollup</i>	13
<i>Cost Performance Drivers – Rollup</i>	14
<i>Downtime Performance Drivers – Rollup</i>	15
HIGH VARIABILITY DRIVERS – ROLL UP	16
<i>Operational Unavailability High Variability Drivers – Rollup</i>	16
<i>Event Frequency (MTBE) High Variability Drivers – Rollup</i>	17
<i>Cost High Variability Drivers – Rollup</i>	18
<i>Downtime High Variability Drivers – Rollup</i>	19
LOW VARIABILITY DRIVERS – ROLL UP	20
<i>Operational Unavailability Low Variability Drivers – Rollup</i>	20
<i>Event Frequency (MTBE) Low Variability Drivers – Rollup</i>	21
<i>Cost Low Variability Drivers – Rollup</i>	22
<i>Downtime Low Variability Drivers – Rollup</i>	23
TURBINE SUMMARY	24
APPENDIX A: PERFORMANCE DRIVERS – FULL TAXONOMY	26
<i>Operational Unavailability Performance Drivers – Full Taxonomy</i>	26
<i>Event Frequency (MTBE) Performance Drivers – Full Taxonomy</i>	27
<i>Cost Performance Drivers – Full Taxonomy</i>	28
<i>Downtime Performance Drivers – Full Taxonomy</i>	29
APPENDIX B: HIGH VARIABILITY DRIVERS – FULL TAXONOMY	30
<i>Operational Unavailability High Variability Drivers – Full Taxonomy</i>	30
<i>Event Frequency (MTBE) High Variability Drivers – Full Taxonomy</i>	31
<i>Cost High Variability Drivers – Full Taxonomy</i>	32
<i>Downtime High Variability Drivers – Full Taxonomy</i>	33
APPENDIX C: LOW VARIABILITY DRIVERS – FULL TAXONOMY	34
<i>Operational Unavailability Low Variability Drivers – Full Taxonomy</i>	34
<i>Event Frequency (MTBE) Low Variability Drivers – Full Taxonomy</i>	35
<i>Cost Low Variability Drivers – Full Taxonomy</i>	36
<i>Downtime Low Variability Drivers – Full Taxonomy</i>	37
APPENDIX D: TAXONOMY & FAILURE MODE SUMMARY	38

Table of Figures

FIGURE B-1: TURBINE TIME ALLOCATION PIE CHART	8
FIGURE B-2: MAJOR PARTS REPLACEMENTS – ALL DATA	9
FIGURE B-3: AVAILABILITY AND UTILIZATION TRENDS.....	10
FIGURE B-4: MEAN DOWNTIME TRENDS.....	10
FIGURE B-5: MTBE, MTBF, MTB FAULT TRENDS	10
FIGURE B-6: MTB SCHEDULED MAINTENANCE TRENDS	10
FIGURE B-7: ANNUAL EVENT AND FAILURE COST TRENDS.....	10
FIGURE B-8: ANNUAL SCHEDULED COST TRENDS	10
FIGURE B-9: PLANT EVENT COUNT TRENDS	11
FIGURE B-10: NATIONAL EVENT COUNT TRENDS	11
FIGURE B-11: EVENT AND EMERGENCY COUNT TRENDS	11
FIGURE B-12: OPERATIONAL UNAVAILABILITY PERFORMANCE DRIVERS – ROLLUP, ALL DATA	12
FIGURE B-13: OPERATIONAL UNAVAILABILITY PERFORMANCE DRIVERS – ROLLUP, 1/1-6/30/2008.....	12
FIGURE B-14: EVENT FREQUENCY PERFORMANCE DRIVERS – ROLLUP, ALL DATA.....	13
FIGURE B-15: EVENT FREQUENCY PERFORMANCE DRIVERS – ROLLUP, 1/1-6/30/2008	13
FIGURE B-16: COST PERFORMANCE DRIVERS – ROLLUP, ALL DATA	14
FIGURE B-17: COST PERFORMANCE DRIVERS – ROLLUP, 1/1-6/30/2008.....	14
FIGURE B-18: DOWNTIME PERFORMANCE DRIVERS – ROLLUP, ALL DATA.....	15
FIGURE B-19: DOWNTIME PERFORMANCE DRIVERS – ROLLUP, 1/1-6/30/2008	15
FIGURE B-20: OPERATIONAL UNAVAILABILITY HIGH VARIABILITY DRIVERS – ROLLUP, ALL DATA	16
FIGURE B-21: OPERATIONAL UNAVAILABILITY HIGH VARIABILITY DRIVERS – ROLLUP, 1/1-6/30/2008	16
FIGURE B-22: EVENT FREQUENCY HIGH VARIABILITY DRIVERS – ROLLUP, ALL DATA	17
FIGURE B-23: EVENT FREQUENCY HIGH VARIABILITY DRIVERS – ROLLUP, 1/1-6/30/2008.....	17
FIGURE B-24: COST HIGH VARIABILITY DRIVERS – ROLLUP, ALL DATA.....	18
FIGURE B-25: COST HIGH VARIABILITY DRIVERS – ROLLUP, 1/1-6/30/2008	18
FIGURE B-26: DOWNTIME HIGH VARIABILITY DRIVERS – ROLLUP, ALL DATA	19
FIGURE B-27: DOWNTIME HIGH VARIABILITY DRIVERS – ROLLUP, 1/1-6/30/2008.....	19
FIGURE B-28: OPERATIONAL UNAVAILABILITY PERFORMANCE DRIVERS – ALL DATA	26
FIGURE B-29: OPERATIONAL UNAVAILABILITY PERFORMANCE DRIVERS – 1/1-6/30/2008.....	26
FIGURE B-30: EVENT FREQUENCY PERFORMANCE DRIVERS – ALL DATA	27
FIGURE B-31: EVENT FREQUENCY PERFORMANCE DRIVERS – 1/1-6/30/2008.....	27
FIGURE B-32: COST PERFORMANCE DRIVERS – ALL DATA.....	28
FIGURE B-33: COST PERFORMANCE DRIVERS – 1/1-6/30/2008	28
FIGURE B-34: DOWNTIME PERFORMANCE DRIVERS – ALL DATA	29
FIGURE B-35: DOWNTIME PERFORMANCE DRIVERS – 1/1-6/30/2008.....	29
FIGURE B-36: OPERATIONAL UNAVAILABILITY HIGH VARIABILITY DRIVERS – ALL DATA.....	30
FIGURE B-37: OPERATIONAL UNAVAILABILITY HIGH VARIABILITY DRIVERS – 1/1-6/30/2008	30
FIGURE B-38: EVENT FREQUENCY HIGH VARIABILITY DRIVERS – ALL DATA.....	31
FIGURE B-39: EVENT FREQUENCY HIGH VARIABILITY DRIVERS – 1/1-6/30/2008	31
FIGURE B-40: COST HIGH VARIABILITY DRIVERS – ALL DATA	32
FIGURE B-41: COST HIGH VARIABILITY DRIVERS – 1/1-6/30/2008.....	32
FIGURE B-42: DOWNTIME HIGH VARIABILITY DRIVERS – ALL DATA.....	33
FIGURE B-43: DOWNTIME HIGH VARIABILITY DRIVERS – 1/1-6/30/2008	33

Table of Tables

TABLE B-1: SUMMARY STATISTICS – PLANT VS. NATIONAL	5
TABLE B-2: PLANT OPERATIONAL UNAVAILABILITY LOW VARIABILITY DRIVERS – ROLLUP, ALL DATA.....	20
TABLE B-3: PLANT OPERATIONAL UNAVAILABILITY LOW VARIABILITY DRIVERS – ROLLUP, 1/1-6/30/2008	20
TABLE B-4: PLANT EVENT FREQUENCY LOW VARIABILITY DRIVERS – ROLLUP, ALL DATA.....	21
TABLE B-5: PLANT EVENT FREQUENCY LOW VARIABILITY DRIVERS – ROLLUP, 1/1-6/30/2008	21
TABLE B-6: PLANT COST LOW VARIABILITY DRIVERS – ROLLUP, ALL DATA	22
TABLE B-7: PLANT COST LOW VARIABILITY DRIVERS – ROLLUP, 1/1-6/30/2008.....	22
TABLE B-8: PLANT DOWNTIME LOW VARIABILITY DRIVERS – ROLLUP, ALL DATA.....	23
TABLE B-9: PLANT DOWNTIME LOW VARIABILITY DRIVERS – ROLLUP, 1/1-6/30/2008	23
TABLE B-10: TURBINE SUMMARY STATISTICS – ALL DATA	24
TABLE B-11: TURBINE SUMMARY STATISTICS – 1/1-6/30/2008	25
TABLE B-12: PLANT OPERATIONAL UNAVAILABILITY LOW VARIABILITY DRIVERS – ALL DATA	34
TABLE B-13: PLANT OPERATIONAL UNAVAILABILITY LOW VARIABILITY DRIVERS – 1/1-6/30/2008.....	34
TABLE B-14: PLANT EVENT FREQUENCY LOW VARIABILITY DRIVERS – ALL DATA	35
TABLE B-15: PLANT EVENT FREQUENCY LOW VARIABILITY DRIVERS – 1/1-6/30/2008.....	35
TABLE B-16: PLANT COST LOW VARIABILITY DRIVERS – ALL DATA	36
TABLE B-17: PLANT COST LOW VARIABILITY DRIVERS – 1/1-6/30/2008	36
TABLE B-18: PLANT DOWNTIME LOW VARIABILITY DRIVERS – ALL DATA	37
TABLE B-19: PLANT DOWNTIME LOW VARIABILITY DRIVERS – 1/1-6/30/2008.....	37
TABLE B-20: EVENT TYPE SUMMARY	41

Summary Statistics

Events Included	Metric	Last 6 Months (1/1-6/30/08)		All Available Data	
		Plant Mean Value	National Mean Value	Plant Mean Value	National Mean Value
All Events	Operational Availability	X%	X%	X%	X%
	Wind Utilization	X%	X%	X%	X%
	Utilization	X%	X%	X%	X%
	MTBE (operating hrs)	X	X	X	X
	Mean Downtime (hrs)	X	X	X	X
	Annual Cost (per Turbine)	\$X	\$X	\$X	\$X
Failures	Intrinsic Availability	X%	X%	X%	X%
	MTBF (operating hrs)	X	X	X	X
	Mean Failure Downtime (hrs)	X	X	X	X
	Annual Failure Cost (per Turbine)	\$X	\$X	\$X	\$X
Faults	MTB Fault (operating hrs)	X	X	X	X
	Mean Fault Downtime (hrs)	X	X	X	X
	Annual Fault Cost (per Turbine)	\$X	\$X	\$X	\$X
Scheduled Maintenance	MTB Scheduled Maintenance (operating hrs)	X	X	X	X
	Mean Scheduled Downtime (hrs)	X	X	X	X
	Annual Scheduled Cost (per Turbine)	\$X	\$X	\$X	\$X

All metrics, including annual cost, are for a single, representative, turbine

Table B-1: Summary Statistics – Plant vs. National

Definitions & Terms

- **Annual Cost:** the expected yearly cost for a single turbine, due to all events
 - **Annual Failure Cost:** the expected yearly cost for a single turbine, due to failures
 - **Annual Fault Cost:** the expected yearly cost for a single turbine, due to faults
 - **Annual Scheduled Cost:** the expected yearly cost for a single turbine, due to scheduled maintenance
- **Availability:** the percent of time a system is ready for use (Note: Availability can have many different definitions and formulas.)
 - **Operational Availability:** the percent of total calendar time that the system is either generating or is ready to generate (i.e., the percent of total calendar time that the system is NOT down for events)

$$= (GeneratingHours + OtherUpTime) / CalendarHours$$
 - **Intrinsic Availability:** the percent of operating and downtime that the system is operating; the percent of time the system is functioning, taking into account only the operating time and unscheduled downtime

$$= MeanTimeBetweenFailureFault / (MeanTimeBetweenFailureFault + MeanFailureFaultDowntime)$$

$$= GeneratingHours / (GeneratingHours + DowntimeDueToFailiuresAndFaults)$$
- **Calendar Hours:** for a given analysis period, the total number of hours
- **Event:** scheduled or unscheduled occurrence that stops the turbine or takes it out of service
- **Event Frequency:** the expected number of events per generating hour = 1/MTBE
- **Failure:** an unplanned event that must be reset or fixed at the turbine
- **Fault:** an unplanned event that can be reset automatically or remotely
- **Generating:** the turbine average output is > 0 kW during the measurement period (typically 10 minutes or 1 hour)

Generation	Definition
None	0% of Rated Capacity
Low	0.01 – 10% of Rated Capacity
Moderate	10 – 90% of Rated Capacity
Rated	> 90% of Rated Capacity

- **Generating Hours:** for a given analysis period, the time the system is Generating
- **Mean Downtime:** the average duration of an event (in hours)
 - **Mean Failure Downtime:** the average duration of an event that is a failure
 - **Mean Fault Downtime:** the average duration of an event that is a fault
 - **Mean Failure/Fault Downtime:** the average duration of an event that is either a failure or fault
 - **Mean Scheduled Downtime:** the average duration of an event that is a scheduled maintenance event

- **MTBE:** Mean Time Between Events: the average number of generating hours between events
 - **MTBF:** Mean Time Between Failures: the average number of generating hours between events that are failures
 - **MTB Fault:** Mean Time Between Faults: the average number of generating hours between events that are faults
 - **Mean Time Between Failure/Fault:** the average number of generating hours between events that are either failures or faults
 - **MTB Scheduled Maintenance:** Mean Time Between Scheduled Maintenance: the average number of generating hours between events that are scheduled maintenance events
- **Other Up Time:** for a given analysis period, the time the system is ready to generate, but not actively generating (i.e., it is idle); the system is neither actively producing nor down for an event
- **Scheduled Maintenance:** a planned event
- **Unavailability:** $1 - \text{Availability}$
- **Utilization:** for a given analysis period, the percent of Calendar Hours that the system was Generating

$$= \text{GeneratingHours} / \text{CalendarHours}$$
- **Wind Hours:** for a given analysis period, the total number of hours that the anemometer registered a mean wind speed of 4 – 25 m/s.

Wind	Definition
Below Cut In	0 – 4 m/s
Low	4 – 15 m/s
Rated	15 – 25 m/s
Above Cut Out	> 25 m/s

- **Wind Utilization:** for a given analysis period, the percent of Wind Hours that the system was Generating

$$= \text{GeneratingHours} / \text{WindHours}$$

Average Time Allocation

		Wind			
		Below Cut In < 4 m/s	Low 4-15 m/s	Rated 15-25 m/s	Above Cut Out > 25 m/s
Generation	Rated, > 90% Nominal Capacity				
	Moderate, 10-90%				
	Low, 0.01-10%				
	None, 0% Turbine Online				
	Turbine Offline				
Unknown					

Time Allocation: All Data




Figure B-1: Turbine Time Allocation Pie Chart

Parts Replacement Summary

This summary illustrates the frequency (“Failure Rate”) and duration (“Mean Downtime”) for failures that lead to parts replacement. Scheduled maintenance, faults, and failures that do not require parts replacement are not included. Failure Rate is the expected number of failures (requiring parts replacement) per calendar year for one turbine. Mean Downtime is the expected number of hours of downtime for each event.




Figure B-2: Major Parts Replacements – All Data

Trends




Figure B-3: Availability and Utilization Trends




Figure B-4: Mean Downtime Trends




Figure B-5: MTBE, MTBF, MTB Fault Trends




Figure B-6: MTB Scheduled Maintenance Trends




Figure B-7: Annual Event and Failure Cost Trends




Figure B-8: Annual Scheduled Cost Trends




Figure B-9: Plant Event Count Trends




Figure B-10: National Event Count Trends





Figure B-11: Event and Emergency Count Trends

Performance Drivers – Roll Up


Performance drivers are events which affect reliability metrics. The following figures illustrate the performance drivers (rolled up to the second level of detail in the taxonomy¹) with the most significant negative effect on the metric listed. **For all these graphs, bigger = worse.** The top performance drivers for the plant are illustrated, along with the National value for these drivers.

Operational Unavailability Performance Drivers – Rollup



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J

Figure B-12: Operational Unavailability Performance Drivers – Rollup, All Data




Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J

Figure B-13: Operational Unavailability Performance Drivers – Rollup, 1/1-6/30/2008


¹ See User's Guide for illustration of taxonomy.

Event Frequency (MTBE) Performance Drivers – Rollup



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J


Figure B-14: Event Frequency Performance Drivers – Rollup, All Data



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J


Figure B-15: Event Frequency Performance Drivers – Rollup, 1/1-6/30/2008

Cost Performance Drivers – Rollup



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J


Figure B-16: Cost Performance Drivers – Rollup, All Data



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J


Figure B-17: Cost Performance Drivers – Rollup, 1/1-6/30/2008

Downtime Performance Drivers – Rollup



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J

Figure B-18: Downtime Performance Drivers – Rollup, All Data




Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J

Figure B-19: Downtime Performance Drivers – Rollup, 1/1-6/30/2008

High Variability Drivers – Roll Up


Variability drivers are events which affect the uncertainty in reliability metrics. The following figures illustrate the variability drivers (rolled up to the second level of detail in the taxonomy) with the most significant negative effect on the certainty of the metric listed. Larger variability implies bigger differences from turbine to turbine and more risk when planning for reliability impacts.

Operational Unavailability High Variability Drivers – Rollup



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J


Figure B-20: Operational Unavailability High Variability Drivers – Rollup, All Data



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J


Figure B-21: Operational Unavailability High Variability Drivers – Rollup, 1/1-6/30/2008

Event Frequency (MTBE) High Variability Drivers – Rollup



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J

Figure B-22: Event Frequency High Variability Drivers – Rollup, All Data



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J

Figure B-23: Event Frequency High Variability Drivers – Rollup, 1/1-6/30/2008

Cost High Variability Drivers – Rollup




Figure B-24: Cost High Variability Drivers – Rollup, All Data

Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J




Figure B-25: Cost High Variability Drivers – Rollup, 1/1-6/30/2008

Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J

Downtime High Variability Drivers – Rollup




Figure B-26: Downtime High Variability Drivers – Rollup, All Data

Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J




Figure B-27: Downtime High Variability Drivers – Rollup, 1/1-6/30/2008

Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J

Low Variability Drivers – Roll Up

Variability drivers are events which affect the uncertainty in reliability metrics. The following figures illustrate the drivers (rolled up to the second level of detail in the taxonomy) that contribute the most to overall certainty in the metric listed. Only drivers that occurred on more than 1 turbine are shown.

Operational Unavailability Low Variability Drivers – Rollup

Component AA
Component BB
Component CC
Component DD
Component EE
Component FF
Component GG
Component HH
Component II
Component JJ
Component KK
Component LL
Component MM
Component NN
Component OO
Component PP
Component QQ
Component RR
Component SS
Component TT

Table B-2: Plant Operational Unavailability Low Variability Drivers – Rollup, All Data

Component AA
Component BB
Component CC
Component DD
Component EE
Component FF
Component GG
Component HH
Component II
Component JJ
Component KK
Component LL
Component MM
Component NN
Component OO
Component PP
Component QQ
Component RR
Component SS
Component TT

Table B-3: Plant Operational Unavailability Low Variability Drivers – Rollup, 1/1-6/30/2008

Event Frequency (MTBE) Low Variability Drivers – Rollup

Component AA
Component BB
Component CC
Component DD
Component EE
Component FF
Component GG
Component HH
Component II
Component JJ
Component KK
Component LL
Component MM
Component NN
Component OO
Component PP
Component QQ
Component RR
Component SS
Component TT

Table B-4: Plant Event Frequency Low Variability Drivers – Rollup, All Data

Component AA
Component BB
Component CC
Component DD
Component EE
Component FF
Component GG
Component HH
Component II
Component JJ
Component KK
Component LL
Component MM
Component NN
Component OO
Component PP
Component QQ
Component RR
Component SS
Component TT

Table B-5: Plant Event Frequency Low Variability Drivers – Rollup, 1/1-6/30/2008

Cost Low Variability Drivers – Rollup

Component AA
Component BB
Component CC
Component DD
Component EE
Component FF
Component GG
Component HH
Component II
Component JJ
Component KK
Component LL
Component MM
Component NN
Component OO
Component PP
Component QQ
Component RR
Component SS
Component TT

Table B-6: Plant Cost Low Variability Drivers – Rollup, All Data

Component AA
Component BB
Component CC
Component DD
Component EE
Component FF
Component GG
Component HH
Component II
Component JJ
Component KK
Component LL
Component MM
Component NN
Component OO
Component PP
Component QQ
Component RR
Component SS
Component TT

Table B-7: Plant Cost Low Variability Drivers – Rollup, 1/1-6/30/2008

Downtime Low Variability Drivers – Rollup

Component AA
Component BB
Component CC
Component DD
Component EE
Component FF
Component GG
Component HH
Component II
Component JJ
Component KK
Component LL
Component MM
Component NN
Component OO
Component PP
Component QQ
Component RR
Component SS
Component TT

**Table B-8: Plant Downtime Low Variability Drivers – Rollup,
All Data**

Component AA
Component BB
Component CC
Component DD
Component EE
Component FF
Component GG
Component HH
Component II
Component JJ
Component KK
Component LL
Component MM
Component NN
Component OO
Component PP
Component QQ
Component RR
Component SS
Component TT

**Table B-9: Plant Downtime Low Variability Drivers – Rollup,
1/1-6/30/2008**

Turbine Summary

Turbine	Operational Availability	Mean Time Between Events (hours)	Average Cost Per Event	Mean Downtime Per Event (hours)
Turbine 0001	X%	X	\$X	X
Turbine 0002	X%	X	\$X	X
Turbine 0003	X%	X	\$X	X
Turbine 0004	X%	X	\$X	X
Turbine 0005	X%	X	\$X	X
Turbine 0006	X%	X	\$X	X
Turbine 0007	X%	X	\$X	X
Turbine 0008	X%	X	\$X	X
Turbine 0009	X%	X	\$X	X
Turbine 0010	X%	X	\$X	X
...

Table B-10: Turbine Summary Statistics – All Data


Turbine	Operational Availability	Mean Time Between Events (hours)	Average Cost Per Event	Mean Downtime Per Event (hours)
Turbine 0001	X%	X	\$X	X
Turbine 0002	X%	X	\$X	X
Turbine 0003	X%	X	\$X	X
Turbine 0004	X%	X	\$X	X
Turbine 0005	X%	X	\$X	X
Turbine 0006	X%	X	\$X	X
Turbine 0007	X%	X	\$X	X
Turbine 0008	X%	X	\$X	X
Turbine 0009	X%	X	\$X	X
Turbine 0010	X%	X	\$X	X
...

Table B-11: Turbine Summary Statistics – 1/1-6/30/2008

Appendix A: Performance Drivers – Full Taxonomy


Performance drivers are events which affect reliability metrics. The following figures illustrate the performance drivers (using the full level of detail in the taxonomy²) with the most significant negative effect on the metric listed.

Operational Unavailability Performance Drivers – Full Taxonomy



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J

Figure B-28: Operational Unavailability Performance Drivers – All Data




Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J

Figure B-29: Operational Unavailability Performance Drivers – 1/1-6/30/2008


² See User's Guide for illustration of taxonomy.

Event Frequency (MTBE) Performance Drivers – Full Taxonomy



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J


Figure B-30: Event Frequency Performance Drivers – All Data



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J


Figure B-31: Event Frequency Performance Drivers – 1/1-6/30/2008

Cost Performance Drivers – Full Taxonomy



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J


Figure B-32: Cost Performance Drivers – All Data



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J


Figure B-33: Cost Performance Drivers – 1/1-6/30/2008

Downtime Performance Drivers – Full Taxonomy



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J

Figure B-34: Downtime Performance Drivers – All Data




Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J

Figure B-35: Downtime Performance Drivers – 1/1-6/30/2008

Appendix B: High Variability Drivers – Full Taxonomy


Variability drivers are events which affect the uncertainty in reliability metrics. The following figures illustrate the variability drivers (using the full level of detail in the taxonomy) with the most significant negative effect on the certainty of the metric listed.

Operational Unavailability High Variability Drivers – Full Taxonomy



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J


Figure B-36: Operational Unavailability High Variability Drivers – All Data



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J


Figure B-37: Operational Unavailability High Variability Drivers – 1/1-6/30/2008

Event Frequency (MTBE) High Variability Drivers – Full Taxonomy



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J


Figure B-38: Event Frequency High Variability Drivers – All Data



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J


Figure B-39: Event Frequency High Variability Drivers – 1/1-6/30/2008

Cost High Variability Drivers – Full Taxonomy



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J


Figure B-40: Cost High Variability Drivers – All Data



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J


Figure B-41: Cost High Variability Drivers – 1/1-6/30/2008

Downtime High Variability Drivers – Full Taxonomy



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J

Figure B-42: Downtime High Variability Drivers – All Data



Downtime Event Type	
1	Component A
2	Component B
3	Component C
4	Component D
5	Component E
6	Component F
7	Component G
8	Component H
9	Component I
10	Component J

Figure B-43: Downtime High Variability Drivers – 1/1-6/30/2008

Appendix C: Low Variability Drivers – Full Taxonomy

Variability drivers are events which affect the uncertainty in reliability metrics. The following table lists the drivers (using the full level of detail in the taxonomy) that contribute most to overall certainty in the certainty of the metric listed. Only drivers that occurred on more than 1 turbine are shown.

Operational Unavailability Low Variability Drivers – Full Taxonomy

Component AA
Component BB
Component CC
Component DD
Component EE
Component FF
Component GG
Component HH
Component II
Component JJ
Component KK
Component LL
Component MM
Component NN
Component OO
Component PP
Component QQ
Component RR
Component SS
Component TT

Table B-12: Plant Operational Unavailability Low Variability Drivers – All Data

Component AA
Component BB
Component CC
Component DD
Component EE
Component FF
Component GG
Component HH
Component II
Component JJ
Component KK
Component LL
Component MM
Component NN
Component OO
Component PP
Component QQ
Component RR
Component SS
Component TT

Table B-13: Plant Operational Unavailability Low Variability Drivers – 1/1-6/30/2008

Event Frequency (MTBE) Low Variability Drivers – Full Taxonomy

Component AA
Component BB
Component CC
Component DD
Component EE
Component FF
Component GG
Component HH
Component II
Component JJ
Component KK
Component LL
Component MM
Component NN
Component OO
Component PP
Component QQ
Component RR
Component SS
Component TT

Table B-14: Plant Event Frequency Low Variability Drivers – All Data

Component AA
Component BB
Component CC
Component DD
Component EE
Component FF
Component GG
Component HH
Component II
Component JJ
Component KK
Component LL
Component MM
Component NN
Component OO
Component PP
Component QQ
Component RR
Component SS
Component TT

Table B-15: Plant Event Frequency Low Variability Drivers – 1/1-6/30/2008

Cost Low Variability Drivers – Full Taxonomy

Component AA
Component BB
Component CC
Component DD
Component EE
Component FF
Component GG
Component HH
Component II
Component JJ
Component KK
Component LL
Component MM
Component NN
Component OO
Component PP
Component QQ
Component RR
Component SS
Component TT

Table B-16: Plant Cost Low Variability Drivers – All Data

Component AA
Component BB
Component CC
Component DD
Component EE
Component FF
Component GG
Component HH
Component II
Component JJ
Component KK
Component LL
Component MM
Component NN
Component OO
Component PP
Component QQ
Component RR
Component SS
Component TT

Table B-17: Plant Cost Low Variability Drivers – 1/1-6/30/2008

Downtime Low Variability Drivers – Full Taxonomy

Component AA
Component BB
Component CC
Component DD
Component EE
Component FF
Component GG
Component HH
Component II
Component JJ
Component KK
Component LL
Component MM
Component NN
Component OO
Component PP
Component QQ
Component RR
Component SS
Component TT

Table B-18: Plant Downtime Low Variability Drivers – All Data

Component AA
Component BB
Component CC
Component DD
Component EE
Component FF
Component GG
Component HH
Component II
Component JJ
Component KK
Component LL
Component MM
Component NN
Component OO
Component PP
Component QQ
Component RR
Component SS
Component TT

Table B-19: Plant Downtime Low Variability Drivers – 1/1-6/30/2008

Appendix D: Taxonomy & Failure Mode Summary

Event Type	Yearly Event Rate ³	Mean Downtime ⁴	Cost/Event	Downtime Cost/Hr
Balance of Structure-Mx	X	X	\$X	\$X
Balance of Structure-Rst	X	X	\$X	\$X
Balance of Structure-Sch	X	X	\$X	\$X
Brake::Mechanical brakes	X	X	\$X	\$X
Brake::Mechanical brakes-Mx	X	X	\$X	\$X
Brake::Mechanical brakes-Sch	X	X	\$X	\$X
Brake::Parking Brake - manual transmission lock-Mx	X	X	\$X	\$X
Brake-Mx	X	X	\$X	\$X
Brake-Rst	X	X	\$X	\$X
Control system	X	X	\$X	\$X
Control system::Anemometer	X	X	\$X	\$X
Control system::Anemometer-Mx	X	X	\$X	\$X
Control system::Anemometer-Rst	X	X	\$X	\$X
Control system::Anemometer-Sch	X	X	\$X	\$X
Control system::Control SCADA	X	X	\$X	\$X
Control system::Control SCADA-Mx	X	X	\$X	\$X
Control system::Control SCADA-Sch	X	X	\$X	\$X
Control system::PLC	X	X	\$X	\$X
Control system::PLC-Mx	X	X	\$X	\$X
Control system::PLC-Rst	X	X	\$X	\$X
Control system::PLC-Sch	X	X	\$X	\$X
Control system::Sensors(static)	X	X	\$X	\$X
Control system::Sensors(static)-Mx	X	X	\$X	\$X
Control system::Sensors(static)-Rst	X	X	\$X	\$X
Control system::UPS	X	X	\$X	\$X
Control system::UPS-Mx	X	X	\$X	\$X
Control system::UPS-Rst	X	X	\$X	\$X
Control system::Wind vane-Mx	X	X	\$X	\$X
Control system-Mx	X	X	\$X	\$X
Control system-Rst	X	X	\$X	\$X
Control system-Sch	X	X	\$X	\$X
Drive Train-Mx	X	X	\$X	\$X
Electrical	X	X	\$X	\$X
Electrical::Circuit breakers and switches	X	X	\$X	\$X
Electrical::Circuit breakers and switches-Mx	X	X	\$X	\$X
Electrical::Circuit breakers and switches-Rst	X	X	\$X	\$X
Electrical::Circuit breakers and switches-Sch	X	X	\$X	\$X
Electrical::Crowbar	X	X	\$X	\$X
Electrical::Crowbar-Mx	X	X	\$X	\$X
Electrical::Crowbar-Rst	X	X	\$X	\$X
Electrical::Crowbar-Sch	X	X	\$X	\$X

³ Yearly Event Rate is the expected number of events per turbine per calendar year.

⁴ Mean Downtime is the expected number of hours of downtime for a single event.

Event Type	Yearly Event Rate³	Mean Downtime⁴	Cost/ Event	Downtime Cost/Hr
Electrical::Main circuit breaker	X	X	\$X	\$X
Electrical::Main circuit breaker-Mx	X	X	\$X	\$X
Electrical::Main circuit breaker-Rst	X	X	\$X	\$X
Electrical::Main circuit breaker-Sch	X	X	\$X	\$X
Electrical::Main contactor-Mx	X	X	\$X	\$X
Electrical::Metering and relays-Mx	X	X	\$X	\$X
Electrical::Pad mounted transformer-Mx	X	X	\$X	\$X
Electrical::Pad mounted transformer-Rst	X	X	\$X	\$X
Electrical::Pad mounted transformer-Sch	X	X	\$X	\$X
Electrical::Power converters-Mx	X	X	\$X	\$X
Electrical::Soft starter-Mx	X	X	\$X	\$X
Electrical::Substation-Mx	X	X	\$X	\$X
Electrical::Substation-Rst	X	X	\$X	\$X
Electrical::Switchgear	X	X	\$X	\$X
Electrical::Switchgear-Mx	X	X	\$X	\$X
Electrical::Switchgear-Rst	X	X	\$X	\$X
Electrical::Switchgear-Sch	X	X	\$X	\$X
Electrical::Transformer-Mx	X	X	\$X	\$X
Electrical::Transformer-Rst	X	X	\$X	\$X
Electrical::Transformer-Sch	X	X	\$X	\$X
Electrical-Mx	X	X	\$X	\$X
Electrical-Rst	X	X	\$X	\$X
Electrical-Sch	X	X	\$X	\$X
Emergency stop-Mx	X	X	\$X	\$X
Emergency stop-Rst	X	X	\$X	\$X
GearBox::Bearings	X	X	\$X	\$X
GearBox::Bearings-Mx	X	X	\$X	\$X
GearBox::Bearings-Rst	X	X	\$X	\$X
GearBox::Bearings-Sch	X	X	\$X	\$X
GearBox::Gearbox casing-Mx	X	X	\$X	\$X
GearBox::Gearbox casing-Rst	X	X	\$X	\$X
GearBox::Gearbox oil system	X	X	\$X	\$X
GearBox::Gearbox oil system-Mx	X	X	\$X	\$X
GearBox::Gearbox oil system-Rst	X	X	\$X	\$X
GearBox::Gearbox oil system-Sch	X	X	\$X	\$X
GearBox::Gears-Rst	X	X	\$X	\$X
GearBox::High speed shaft-Mx	X	X	\$X	\$X
GearBox::High speed shaft-Rst	X	X	\$X	\$X
GearBox-Mx	X	X	\$X	\$X
GearBox-Rst	X	X	\$X	\$X
GearBox-Sch	X	X	\$X	\$X
Generator	X	X	\$X	\$X
Generator::Commutator and brushes	X	X	\$X	\$X
Generator::Commutator and brushes-Mx	X	X	\$X	\$X
Generator::Commutator and brushes-Rst	X	X	\$X	\$X
Generator::Commutator and brushes-Sch	X	X	\$X	\$X

Event Type	Yearly Event Rate³	Mean Downtime⁴	Cost/Event	Downtime Cost/Hr
Generator::Contactor	X	X	\$X	\$X
Generator::Contactor-Mx	X	X	\$X	\$X
Generator::Converter	X	X	\$X	\$X
Generator::Converter-Mx	X	X	\$X	\$X
Generator::Converter-Rst	X	X	\$X	\$X
Generator::Converter-Sch	X	X	\$X	\$X
Generator::Encoder	X	X	\$X	\$X
Generator::Encoder-Mx	X	X	\$X	\$X
Generator::Encoder-Rst	X	X	\$X	\$X
Generator::Encoder-Sch	X	X	\$X	\$X
Generator::Exciter-Sch	X	X	\$X	\$X
Generator::Generator bearings	X	X	\$X	\$X
Generator::Generator bearings-Mx	X	X	\$X	\$X
Generator::Generator bearings-Sch	X	X	\$X	\$X
Generator::Generator cooling system	X	X	\$X	\$X
Generator::Generator cooling system-Mx	X	X	\$X	\$X
Generator::Generator cooling system-Rst	X	X	\$X	\$X
Generator::Generator shaft-Mx	X	X	\$X	\$X
Generator::Insulation-Mx	X	X	\$X	\$X
Generator::Overspeed sensor	X	X	\$X	\$X
Generator::Overspeed sensor-Mx	X	X	\$X	\$X
Generator::Overspeed sensor-Rst	X	X	\$X	\$X
Generator::Wiring/Cables-Mx	X	X	\$X	\$X
Generator::Wiring/Cables-Rst	X	X	\$X	\$X
Generator::Wiring/Cables-Sch	X	X	\$X	\$X
Generator-Mx	X	X	\$X	\$X
Generator-Rst	X	X	\$X	\$X
Generator-Sch	X	X	\$X	\$X
Maintenance::Maintenance (12-month)-Sch	X	X	\$X	\$X
Maintenance::Maintenance (18-month)-Sch	X	X	\$X	\$X
Maintenance::Maintenance (3-month)-Sch	X	X	\$X	\$X
Maintenance::Maintenance (6-month)-Sch	X	X	\$X	\$X
Maintenance::Testing-Mx	X	X	\$X	\$X
Maintenance-Sch	X	X	\$X	\$X
Met Tower::Wind vane-Rst	X	X	\$X	\$X
Met Tower-Mx	X	X	\$X	\$X
Pitch system::Blade pitch bearing-Mx	X	X	\$X	\$X
Pitch system::Embedded control system	X	X	\$X	\$X
Pitch system::Embedded control system-Mx	X	X	\$X	\$X
Pitch system::Embedded control system-Rst	X	X	\$X	\$X
Pitch system::Pitch hydraulics	X	X	\$X	\$X
Pitch system::Pitch hydraulics-Mx	X	X	\$X	\$X
Pitch system::Pitch hydraulics-Rst	X	X	\$X	\$X
Pitch system::Pitch hydraulics-Sch	X	X	\$X	\$X
Pitch system-Mx	X	X	\$X	\$X
Pitch system-Rst	X	X	\$X	\$X

Event Type	Yearly Event Rate³	Mean Downtime⁴	Cost/Event	Downtime Cost/Hr
Rotor	X	X	\$X	\$X
Rotor::Blade	X	X	\$X	\$X
Rotor::Blade-Mx	X	X	\$X	\$X
Rotor::Blade-Rst	X	X	\$X	\$X
Rotor::Blade-Sch	X	X	\$X	\$X
Rotor::De-icing system-Mx	X	X	\$X	\$X
Rotor::De-icing system-Rst	X	X	\$X	\$X
Rotor::Hub-Mx	X	X	\$X	\$X
Rotor::Hub-Sch	X	X	\$X	\$X
Rotor::Root attachment-Sch	X	X	\$X	\$X
Rotor-Mx	X	X	\$X	\$X
Slip Rings	X	X	\$X	\$X
Slip Rings-Sch	X	X	\$X	\$X
Structure::Foundation-Sch	X	X	\$X	\$X
Structure::Nacelle	X	X	\$X	\$X
Structure::Nacelle-Mx	X	X	\$X	\$X
Structure::Nacelle-Rst	X	X	\$X	\$X
Structure::Nacelle-Sch	X	X	\$X	\$X
Structure::Tower-Mx	X	X	\$X	\$X
Structure::Tower-Sch	X	X	\$X	\$X
Structure-Mx	X	X	\$X	\$X
Structure-Rst	X	X	\$X	\$X
Structure-Sch	X	X	\$X	\$X
Unidentified Failure-Mx	X	X	\$X	\$X
Unidentified Fault-Rst	X	X	\$X	\$X
Yaw System::Yaw bearing-Mx	X	X	\$X	\$X
Yaw System::Yaw brake-Mx	X	X	\$X	\$X
Yaw System::Yaw brake-Rst	X	X	\$X	\$X
Yaw System::Yaw control system	X	X	\$X	\$X
Yaw System::Yaw control system-Mx	X	X	\$X	\$X
Yaw System::Yaw control system-Rst	X	X	\$X	\$X
Yaw System::Yaw lubrication system-Mx	X	X	\$X	\$X
Yaw System::Yaw motor/hydraulics	X	X	\$X	\$X
Yaw System::Yaw motor/hydraulics-Mx	X	X	\$X	\$X
Yaw System::Yaw motor/hydraulics-Rst	X	X	\$X	\$X
Yaw System-Mx	X	X	\$X	\$X
Yaw System-Rst	X	X	\$X	\$X

Table B-20: Event Type Summary

Appendix C: Pro-Opta

Sandia has been heavily involved in modeling, simulation, and optimization of system reliability, maintainability, and availability for many years. The Pro-Opta software package is a reliability analysis and optimization program developed by Sandia National Laboratories. Pro-Opta is intended to provide information needed to make strategic decisions in the competitive marketplace. It has been shown that not only can Pro-Opta provide valuable information in the estimation of fleet performance using existing failure and repair data, but this data can also be mined for additional information of significant value. Pro-Opta can provide guidance regarding investment strategies that result in fleet availability levels superior to those achievable without supporting analysis (Sand 2006-7218).

The following few paragraphs describe the basic purpose of each of the six Pro-Opta modules. (Additional information about Pro-Opta can be found in the Pro-Opta User Manuals, which come installed with the Pro-Opta software.)

Import Setup

The importation of field data into Data Analyzer requires a Pro-Opta configuration file. Pro-Opta has a default configuration that might serve the requirements for importing your field data. If not, a configuration built specifically for your field data can be generated using Import Setup. Thus, running Import Setup is often a preparatory step towards importing field data into Data Analyzer. It links the internal Pro-Opta field names to your preferred terminology. It also allows you to select the fields to include in the analysis and to select the types of analysis results to generate.

Data Analyzer

Data Analyzer imports field data and analyzes the data according to the configuration you select. In order to use Data Analyzer the field data must contain records of the failure events that occurred on your equipment. Each record must define which machine went down, the date and time of the event, a specific and unique reason why the event occurred (known as a failure mode), and how long the machine was down, in hours. Data Analyzer analyzes this equipment failure event data in several ways. It is easy to determine which types of events and which machines are causing the most problems. This helps you make better judgments as to which areas you should focus on to best improve reliability. An optimization study can be built on a model generated by Data Analyzer.

Data Manager

Use the Data Manager to build a Pro-Opta failure mode library. Such a library is required for Pro-Opta design analysis. Entering failure mode data is similar to entering data onto a spreadsheet. If you are more comfortable using a spreadsheet, enter the data there and import it to Data Manager. There are a few required properties for each failure mode: Failure Mode ID,

Failure Mode Name, nominal failure rate or nominal failure probability, and nominal downtime. It is likely that there is uncertainty or variability in the values for failure rates, downtimes, and failure probabilities. To capture this uncertainty, you are encouraged to assign probability distributions to these properties. Guidance on the selection of distribution type is provided in the Pro-Opta Design Manual. The selection depends on how much supporting data you have.

Fault Tree Interface

Whether analyzing a new design or an existing system, use the Fault Tree Interface to enter your fault tree for use by Pro-Opta. Begin by assigning a name to the top event that is appropriate for system failure. From there construct the tree by successively defining the children of each event using the immediate cause concept. It is in this interface where cost information can be input and correlations amongst failure modes can be defined. The Fault Tree Interface analyzes a fault tree in two steps. First, it uses the laws of Boolean algebra to express an equivalent failure equation in disjunctive form, known traditionally as a collection of cutsets. Second, using the properties of the associated failure mode library and any cost and correlation information, the Fault Tree Interface quantifies a set of performance measures for the fault tree. View the results of the fault tree analysis using the Results Module.

Results Module

The Results Module provides various ways to examine system performance measures (MTBF, availability, downtime, reliability, failure probability, and cost). It is most useful when the failure modes have been assigned probability distributions. In that case the performance measures are examined in a statistical framework. The display of the values that a performance measure takes on can be either in tabular form (summary statistics, the raw data) or graphical form (histograms, cumulative distribution functions, Pareto charts). The primary events that are most important in determining the magnitude of the performance measure can be found under the Sensitivity menu. The primary events that are most important in determining the uncertainty in the performance measure can be found under the Uncertainty menu.

Optimizer

Optimizer is designed to perform reliability and spare parts optimizations. Performance optimization determines the best set of modifications or component upgrades to improve equipment reliability within the reliability and cost constraints specified by the user. For performance analysis, Optimizer operates on models developed by Data Analyzer or Fault Tree Interface, or a group of the latter. Spare Parts optimization determines the best set of spare parts to keep on hand, improving equipment availability within the downtime and cost constraints specified by the user. For spares analysis, Optimizer operates on models developed by Data Analyzer or Fault Tree Interface, or directly on a file of demand rates.

Appendix D: Blade Reliability Survey

In April 2008 a blade reliability survey was conducted by phone representing four plants with over 400 turbines, most of which had been in service over three years. Results are as follows:

- **Around 18 years MTBF per turbine**
 - **Highly variable – MTBF per blade is between 15 and 600 years**
 - **Anecdotal stories of all blades failing**
- **About 80 blade replacements – 40 (half) at one plant**
- **Replacement times range from 2 weeks to 2 months**

Blade issues cited include:

- **Manufacturing issues – waviness and overlaid laminates**
- **Bad bonds, delamination, and voids**
- **Leading edge erosion**
- **Trailing edge splits**
- **Lightning – comments:**
 - ◆ At one plant every blade has been struck at least once
 - ◆ Many repairs and replacements
 - ◆ Scorching and splits
 - ◆ Manageable problem (relative to gearboxes)

The following table summarizes the information found in the survey, with one row for each responding plant.

<i>Years of operation</i>	<i>Number of turbines</i>	<i>Type of defect ; number of replacements</i>	<i>Comments</i>
0-5	100+	Lightning	Lots of strikes
5-10	100+	Manufacturing – laminations, voids, leading edge erosion, trailing; 6 blades per year replaced one at a time	Every blade struck by lightning once, \$100k spent per year on repairs
0-5	0-50	Delamination, voids; 15 blades replaced	Clean every year
5-10	100+	QC – leading edge erosion, bug fouling; 40 blades replaced	Clean when gearboxes are changed

DISTRIBUTION:

Mark Anderson
Centennial Power, Inc.
1150 West Century Avenue
PO Box 5558
Bismarck, ND 58506

Paul Baker
Moventas, Inc.
8823 N. Harborgate Street
Portland, OR 97203

Dr. Phillip O. Barry
NAWRTC at Mesalands Community College
911 South Tenth Street
Tucumcari, NM 88401

Harvey Benes
Nebraska Public Power District
PO Box 310
402 East State Farm Road
North Platte, NE 69103-0310

Roy Blackshear
AEP, Desert Sky Wind Farm lp
PO Box 518
Iraan, TX 79744

Ken Bolin
XCEL Energy
1225 17th Street, #483
Denver, CO 80202-5534

C.P. Sandy Butterfield
NREL/NWTC
1617 Cole Boulevard MS 3811
Golden, CO 80401

Craig Christensen
Clipper Windpower Technology, Inc.
6305 Carpinteria Ave., Suite 300
Carpinteria, CA 93013

Mike Curley
NERC
116-390 Village Blvd.
Princeton, NJ 08540

Warren Ault
LM Glasfiber ND Inc.
117 N. Jefferson Street, Suite 201
Chicago, IL 60661

Larry Barr
enXco
17298 Commerce Way
Tracy, CA 95377

Benjamin Bell
Garrad Hassan America, Inc.
43 Norway Hill Road
Hancock, NH 03449

Daniel W. Bernadett
AWS Truwind LLC
463 New Karner Road
Albany, NY 12205

Eckart Bodenbach
Winery Drive Systems Corporation
950 Tollgate Road
Elgin, IL 60123

Geoffrey Bratton
JP Morgan Capital Corporation
10 South Dearborn Street
Chicago, IL 60603

Jon N. Chafin
Wind Hunter
821 East Dove Loop Road, Suite 2425
Grapevine, TX 76051

R. Nolan Clark
USDA - Agricultural Research Service
PO Drawer 10
Bushland, TX 79012

Salvatore A. DellaVilla
Strategic Power Systems, Inc.
11121 Carmel Commons Blvd. Suite 100
Charlotte, NC 28226

Edgar DeMeo
Renewable Energy Consulting Services
2791 Emerson St.
Palo Alto, CA 94306

Tracy Deadman
AES Wind Generation
4300 Wilson Boulevard
Arlington, VA 22203

Carlos J. Diaz
Edison Mission Energy-Midwest
Generation EME, LLC
440 South LaSalle Street, Suite 3500
Chicago, IL 60605

Philip K. Dutton
206 Reveille Road
Austin, TX 78746

Scott Eatherton
AES Wind Generation
14740 Altamont Pass Road
Tracy, CA 95391

Neal Emmerton
Babcock & Brown
777 Tahquitz Canyon Way, Suite 200-13
Palm Springs, CA 92262

Margaret M. Ganczak
Vestas Americas
1881 SW Naito Parkway, Suite 100
Portland, OR 97201

Randall Grayson
enXco
215 111th Street
Lake Wilson, MN 56151

Gary Hackett
Portland General Electric Company
121 SW Salmon Street
Portland, OR 97204-2908

Ted De Rocher
Caithness Operating Company, LLC
9790 Gateway Dr., Suite 220
Reno, NV 89521

Chris E. Derickson
Nebraska Public Power District
PO Box 310, 402 East State Farm Road
North Platte, NE 69103-0310

John R. Dunlop
American Wind Energy Association
448 Morgan Avenue South
Minneapolis, MN 55405

Marc Dworkin
Reunion Power LLC
PO Box 2049
Manchester Center, VT 05255

Ahmed Elgamal
University of California-San Diego
9500 Gilman Drive #0085
San Diego, CA 92093-0085

Miguel Ezpeleta
Acciona Wind Energy USA, LLC
101 North Wacker Drive, Suite 610
Chicago, IL 60606

Ben M. Givens
American Electric Power
1423 CR 131, Trent Wind Farm, L.P.
Trent, TX 79561-3029

AnneMarie Graves
Garrad Hassan America, Inc.
11770 Bernardo Plaza Court, Suite 209
San Diego, CA 92128

Bruce Hamilton
PPM Energy, Inc.-A Scottish Power Company
1125 NW Couch, Suite 700
Portland, OR 97209-4129

Bruce Hammett
WECS Electric Supply, Inc.
Box 580276, 19465-3A N. Indian Avenue
North Palm Springs, CA 92258-0276

James Heenan
GE Energy
2 Central Quay, 89 Hydepark Street
Glasgow, G3 8 BW
Great Britain

Peter Hjuler Jensen
Riso National Laboratory
Station for Wind Turbines, Box 49
DK-4000, Denmark

Gary Kanaby
Knight & Carver Yacht Center
2423 Hoover Avenue
National City, CA 91950

Carl Knowlan
Horizon Wind Energy
808 Travis Street, Suite 700
Houston, TX 77002

Benjamin Lanz
IMCORP
179 Middle Turnpike
Storrs, CT 06268

S. Doug Levitt
CalWind Resources Inc.
2659 Townsgate Rd. #122
Westlake Village, CA 91361

James Locke
AIRBUS North America Engineering, Inc.
213 Mead Street
Wichita, KS 67202

Shaw Makaremi
Clipper Windpower
6305 Carpinteria Ave.
Carpinteria, CA 93013

David A. Healy
MidAmerican Energy
666 Grand Avenue, PO Box 657
Des Moines, IA 50309-2506

James Holly
BP Alternative Energy North America Inc.
501 Westlake Park Boulevard
Houston, TX 77079

Thomas Jonsson
iQwind LLC
8208 NW 30th Terrace
Miami, FL 33122

Morten Karulf
ABB Danish Wind Team
Meterbuen 33
8382 Skovlunde
Denmark

Clifford Lange
841 Byerley Ave.
San Jose, CA 95125

Scott Larwood
1120 N. Stockton St.
Stockton, CA 95203

Steve Lockard
TPI Composites, Inc.
373 Market Street
Warren, RI 02885-0367

James Lyons
Novus Energy Partners
201 North Union St., Suite 350
Alexandria, VA 22314

Lance Manuel
University of Texas at Austin
1 University Station, C1748
Austin, TX 78712

Shane Mawhinney
B9 Energy (O&M) Ltd.
Willowbank Road
Milbrook Industrial Estate
Larne, Co. Antrim
N. Ireland, BT402SF
United Kingdom

Glenn Melski
Enel North America, Inc.
One Tech Drive, Suite 220
Andover, MA 01810

Steve Mikel
Suzlon Wind Energy Corporation
620 3RD Avenue
Pipestone, MN 56164

Jim Morgan, LCDR, USN
Mesalands Community College
911 South Tenth Street
Tucumcari, NM 88401

Walt Musial
NREL/NWTC
1617 Cole Boulevard MS 3811
Golden, CO 80401

Energy Research Centre of the Netherlands
T.S. Obdam
PO Box 1
1755 ZG Petten
The Netherlands

Venkata Subbaiah Pasupulati
Oak Creek Energy Systems, Inc.
14633 Willow Springs Rd.
Mojave, CA 93501

Jon Powers
CalWind Resources, Inc.
2659 Townsgate Road #122
Westlake Village, CA 91361-2738

Brian McNiff
McNiff Light Industry
43 Dog Island Road
Harborside, ME 04642

Jim Mikel
Energy Maintenance Service, LLC
PO Box 158
Gary, SD 57237-0158

Amir Mikhail
Clipper Windpower Technology, Inc.
6305 Carpinteria Ave., Suite 300
Carpinteria, CA 93013

Larry Mumper
SKF USA Inc.
1510 Gehman Road, PO Box 332
Kulpsville, PA 19443-0332

Library NWTC (5)
NREL/NWTC
1617 Cole Boulevard
Golden, CO 80401

Tim Olsen
Tim Olsen Consulting
1428 S. Humboldt St.
Denver, CO 80210

R.Z. Poore
Global Energy Concepts, LLC
1809 7th Ave.
Seattle, WA 98101

Pep Prats
Ecotecnia
Roc Boronat 78
8005 Barcelona
Spain

Ian Prowell (10)
University of California-San Diego
9500 Gilman Drive #0085
San Diego, CA 92093-0085

Paul Rowan
MLS Electrosystem
9333 Timber Trail
Pittsburgh, PA 15237

Steve St. Clair
Puget Sound Energy
PO Box 97034, PSE-09S
Bellevue, WA 98009-9734

Brian Smith
NREL/NWTC
1617 Cole Boulevard MS 3811
Golden, CO 80401

Sandy Smith
Utility Wind Integration Group
PO Box 2787
Reston, VA 20195

Cece Sterling (10)
Office of Wind and Hydropower Technologies
EE-2B Forrestal Building
U.S. Department of Energy
1000 Independence Ave. SW
Washington, DC 20585

Britt Theismann
American Wind Energy Association
1101 14th Street, NW, 12th Floor
Washington, DC 20005-5601

Case P. van Dam
Dept. of Mechanical & Aerospace Eng.
University of California at Davis
One Shields Avenue
Davis, CA 95616-5294

Dan Rottler
Puget Sound Energy
PO Box 97034, PSE-09S
Bellevue, WA 98009-9734

Rene Rysbergen
B9 Energy O&M Ltd
Millbrook Industrial Estate
Larne, Northern Ireland
BT40 2SF, United Kingdom

Michael Schmidt
Iowa Lakes Community College
19 South 7 Street
Estherville, IA 51334-2234

Paul Smith
Puget Sound Energy
PO Box 97034, PSE-09S
Bellevue, WA 98009-9734

Robert F. Steele Jr.
Strategic Power Systems, Inc.
11016 Rushmore Drive
Frenette Building Suite 275
Charlotte, NC 28277

Andrew Swift
Texas Tech University
Civil Engineering
PO Box 41023
Lubbock, TX 79409-1023

William A. Vachon
W. A. Vachon & Associates
PO Box 149
Manchester, MA 01944

Chris Walford
Puget Sound Energy
PO Box 97034, PSE-09S
Bellevue, WA 98009-9734

Charles White
B9 Energy (O&M) Ltd.
Willowbank Road,
Milbrook Industrial Estate
Larne, Co. Antrim,
N. Ireland, BT402SF
United Kingdom

Eric White
AWS Truewind LLC
463 New Karner Road
Albany, NY 12205

INTERNAL DISTRIBUTION:

MS 0557 D.T. Griffith, 1523
MS 1138 K. Bauer, 6324
MS 1108 J. Stinebaugh, 6332
MS 1108 J. Torres, 6332
MS 1124 T.D. Ashwill, 6333
MS 1124 D.E. Berg, 6333
MS 1124 S.M. Gershin, 6333
MS 1124 R.R. Hill, 6333 (15)
MS 1124 W. Johnson, 6333
MS 1124 D.L. Laird, 6333
MS 1124 J. Paquette, 6333
MS 1124 M.A. Rumsey, 6333
MS 1124 P.S. Veers, 6333
MS 1124 J.R. Zayas, 6333
MS 1124 Wind Library, 6333 (5)
MS 1033 A. Ellis, 6335
MS 0734 E. Stechel, 6339
MS 1188 B. Thompson, 6342
MS 1188 D. Briand, 6345
MS 1188 R. Cranwell, 6345
MS 1188 A. Nanco, 6345
MS 1188 V. Peters, 6345
MS 0899 Technical Library, 9536 (Electronic)



Sandia National Laboratories